

Anthony Esson, Architect
PO Box 479
Gaylord, Michigan 49734

West Branch Rose City Area Schools
Ogemaw Heights High School Track Replacement

March 1, 2021

Project No. 263-18J

ADDENDUM NO. 2

This Addendum is being issued for the purpose of modifying and/or clarifying the original Bidding Documents dated February 12, 2021 and shall take precedence over them.

All work included herein shall be in accordance with the general requirements of the original bidding documents, except as specifically noted herein.

This Addendum is being sent to all known plan holders, suppliers, plan rooms, and governmental agencies having received Bidding Documents.

Supplemental Documents Issued: None

Item No. 1: Restoration Clarification: Bidders shall include the cost to prep for and provide and install sod in all disturbed areas inside the track (everywhere except the football field which shall remain), in lieu of seed and mulch.

Item No. 2: Electrical Feeder Clarification: It is the intent of the design to route new feeders across the football field without damage to irrigation lines or other utilities that may be routed in the field area, and to minimize damage to field turf by installation with directional boring.

END OF ADDENDUM NO. 2