

Anthony Esson, Architect
PO Box 479
Gaylord, Michigan 49734

West Branch Rose City Area Schools
SF1.5 Surline MS Two-Story HVAC Improvements and
Rose City Elementary DDC Controls

January 24, 2022

Project No. 263-18M

ADDENDUM NO. 1

This Addendum is being issued for the purpose of modifying and/or clarifying the original Bidding Documents dated December 17, 2021 and shall take precedence over them.

All work included herein shall be in accordance with the general requirements of the original bidding documents, except as specifically noted herein.

This Addendum is being sent to all known plan holders, suppliers, plan rooms, and governmental agencies having received Bidding Documents.

Supplemental Documents Issued: None

Item No. 1: Refer to Surline MS Two-Story HVAC Improvements Drawings; Sheet E5.1. The feeder for new panel "2EA" may be either 1 run of 4#600, #3G or (2 parallel runs) # 3/0 w/ #3 G.

Item No. 2: Refer to Surline MS Two-Story HVAC Improvements Drawings; Sheet E5.1. The new sub-panels are to be NEMA 1 rated.

END OF ADDENDUM NO. 1