

Anthony Esson, Architect
PO Box 479
Gaylord, Michigan 49734

West Branch Rose City Area Schools
OHHS Partial Reroofing

May 18, 2022

Project No. 263-18N

ADDENDUM NO. 2

This Addendum is being issued for the purpose of modifying and/or clarifying the original Bidding Documents dated April 15, 2022 and shall take precedence over them.

All work included herein shall be in accordance with the general requirements of the original bidding documents, except as specifically noted herein.

This Addendum is being sent to all known plan holders, suppliers, plan rooms, and governmental agencies having received Bidding Documents.

Supplemental Documents Issued: None

Item No. 1: Reuse existing edge metal: During the pre-bid walk-thru, it was determined that the existing snap-on aluminum fascia is in good condition and can be removed and replaced. Bidders are to include the cost of removal and reinstallation of existing edge metal in the Bid in lieu of removal and replacement with new.

END OF ADDENDUM NO. 2