

Anthony Esson, Architect  
PO Box 479  
Gaylord, Michigan 49734

Ellsworth Community Schools  
Elementary School Boiler Replacement Project

September 30, 2022

Project No. 293-22

**ADDENDUM NO. 1**

This Addendum is being issued for the purpose of modifying and/or clarifying the original Bidding Documents dated July 29, 2022 and shall take precedence over them.

All work included herein shall be in accordance with the general requirements of the original bidding documents, except as specifically noted herein.

This Addendum is being sent to all known plan holders, suppliers, plan rooms, and governmental agencies having received Bidding Documents.

Supplemental Documents Issued:           None

Item No. 1:       Include in the Bid, the cost of materials and labor to insulate existing hydronic heating and domestic water piping in the mechanical room where insulation is missing at elbows and fittings as observed and discussed during the Pre-bid Meeting.

**END OF ADDENDUM NO. 1**